

D₀ Conversion




PAPTAC Bleaching Committee
October 2014


B Bleach

B Bleach Detail

Low Consistency
 D_0 stage




B Bleach




- Increase stock consistency and retention time at D_0
- Reduce filtrate volume, reduce bleach plant COD
- Reducing ClO_2 consumption in the overall bleaching process
- Increase storage capacity in B bleach
- Reduce installed horsepower in process
- Improve process temperature with reducing water dilution dependence and adding a steam mixer to medium consistency stock

- Remove steam mixer from T40A and recondition. Install steam mixer below washer 45B
- Install drop chute to basement MC chute. Install MC chute and pump
- Install SS piping on discharge of MC Pump to ClO₂ mixer


Old LC D₀




Interim LC D₀




Interim LC D₀



Final MC D₀ Stage






Condition and results @ Avg. 255admt/d




| | Consist (%) | Retention Time (min) | Temp. (° C) | D₀ Kappa Factor | Brightness D₀ (EOP) | D1 Kappa Factor |
|---------------------------|--------------------|-----------------------------|--------------------|-----------------------------------|---------------------------------------|------------------------|
| LC D ₀ | 3.2 | 48.7 | 43.3 | 0.17 | 46.6 | 0.95 |
| Interim LC D ₀ | 3.4 | 56.5 | 53.3 | 0.17 | 49.1 | 0.83 |
| MC D ₀ | 10.0 | 143.8 | 58.9 | 0.17 | 54.5 | 0.77 |

B Bleach Chemical Usage Results



| Energy Savings | | |
|--|---------------|-------------|
| NaClO ₃ to ClO ₂ Conversion Factor | 1.67 | |
| NaClO ₃ Conversion to ClO ₂ efficiency | 93.70% | |
| Total NaClO ₃ Savings | 2,030 | Tonnes |
| NaClO ₃ Electrical Energy Input | 5,175 | Kw-hr/tonne |
| Total Electrical Energy Savings | 10,503,278 | Kw-hr |
| Total Electrical Energy Savings | 37,812 | GJ |



| CIO2 Efficiency | | | | | | |
|---|--------------------------|----------------|-------------------|----------------------|------------------------|-------------|
| | CIO2 Generation (tonnes) | Avg Daily CIO2 | Production (ADMT) | Avg Daily Production | Tonnes Pulp/Tonne CIO2 | kg/BADt |
| Jan 1 2009 to Oct 15, 2009 | 6,420 | 22 | 189,062 | 659 | 29 | 34.0 |
| Jan 1, 2010 to Oct 15, 2010 | 8,261 | 29 | 261,527 | 911 | 32 | 31.6 |
| Jan1 2013 to Oct 31, 2013 | 7,939 | 26.6 | 292,272 | 965 | 36 | 27.2 |
| Projected Efficiency and CIO2 Savings- 2012: | | | | | | |
| Projected Efficiency Jan1 2012 to Oct 15, 2012 | 6,800 | 24 | 261,527 | 911 | 39 | 26.0 |
| Projected Annual Savings - Tonnes of CIO2 (340,000 TPY) | 2,735 | | | | | |
| Factor by 0.4 | 1,094 | | | | 32.5 | |
| Achieved Efficiency and CIO2 Savings- 2012: | | | | | | |
| Jan1 2012 to Oct 15, 2012 | 8,121 | 28 | 317,456 | 1,102 | 39 | 25.6 |
| Annual Savings - Tonnes of CIO2 (340,000 TPY) | 2,847 | | | | | |
| Factor by 0.4 | 1,139 | | | | 32.7 | |


- Overall ClO₂ usage improvement in B bleach
- B Bleach D₀ maintenance cost reduction
- 200hp power usage reduction
- Storage capacity increase in B bleach
- 10% total chemical cost reduction

Thank You







Tower 10B Kappa Factor
All Run




Tower 10B Kappa Factor
All Run



W55B COLOUR
Washer 55B Colour
All Run




KAPPA_LINE_1/BRIGHTNESS_OUT
B Bleach Pre D1 Brightness
All Run




B Bleach Steam


B_BLEACH/STEAM_\$_BADT.F_CV
B Bleach Steam Real Time Usage
All Run



B_BLEACH/STEAM_\$_BADT.F_CV
B Bleach Steam Real Time Usage
All Run




B-KAPPA-60/T60B_KAPPA.F_CV
Tower 40B Kappa
All Run



Avg: 4.73
StdDev: 0.6
Min: 2
Max: 7
Count: 275942
Excluded: 1978

95%: 5.8
90%: 5.51
75%: 5.02
50%: 4.71
25%: 4.41
10%: 4.06
5%: 3.84

Harmac Pacific Pulp Operations




Remove steam mixer from T40A and recondition. Install steam mixer below washer 45B.

Install drop chute to basement MC chute. Install MC chute and pump.

Install SS piping on discharge of MC Pump to ClO₂ mixer.


MC pump is controlled so that all stock falling into the drop leg is pumped further at the higher possible consistency. Pulp level in the drop leg will be measured. The flow rate through the pump can be adjusted by a control valve (it could be considered to combine the control valve strategy by changing the speed of the pump).



| | | |
|-------------|----------|---------|
| ? | Kappa | 23.9 |
| | Kappa F. | 0.175 |
| | Target | 0.175 |
| AUTO | | 461 Sec |


| | |
|-------------|-------|
| RESIDUAL | 276.6 |
| RAW BRT | 25.0 |
| COMP BRT | 31.3 |
| IMAN | |
| % Applied | 1.6 |
| IMAN | |
| CI02 | 100.8 |
| RCAS | |


- B Bleach
- NFP**
- ARMAC PULP OPERATIONS
- Washers
- Chem Ctrl
- D10 - W45B
- 10B - W15B**
- 20B - W25B
- 40B - W55B
- 60B - W65B
- 70B - W75B
- 80B - W85B
- Water
- Data Entry
- Pin Data
- Misc.
- Setup
- Kappa
- Showers
- % Applied ON**
- Flution Control ON**
- 0 Kappa Factor
0.174
- 0 Kappa Factor
0.700
- Total Clo2
30.2 kg/t
- Total NaOH
22.2 kg/t
- Total H2O2
2.9 kg/t
- Total Steam
608. kg/t



NO. 1 MACHINE BRIGHTNESS

ALL FB GRADES (B LINE SINCE SEP 2009)





Overview

Kappa

Brightness

Consistency

Models

2&3 BSW Channel A

Status **Adjusting consistency to 0.2%**

Kappa **32.05** Kappa (Avg. of last 5 samples) **32.09**


Last Sample **12:50**

Cedar Grades

Hem/Fir Grades

Channel Enable

Sampler ON



T10B Channel B

Status **Standby (Waiting)**

Kappa **23.96** Kappa (Avg. of last 5 samples) **23.57**

Kappa Tolerance HI **35.0** LO **11.0**


Last Sample **13:4**

Cedar Grades

Hem/Fir Grades

Channel Enable

Sampler ON



T60B Pre D1 [KappaQ Line 1]

Status **Waiting...**

Kappa **4.69**


Kappa Tolerance HI **7.2** LO **3.5**

Last Sample **12:52**



Line Enable


Sampler ON



Chlorate & Caustic: Bleach Plant



Average Chlorate Usage Kg/t



Average Caustic Usage Kg/t

